

**Site Survey of Selected Items**  
For  
**Compliance with the Americans with Disabilities Act (ADAAG)**  
and  
**Title 24 of the California Building Code**



**Early College High School**  
700 Wilshire Boulevard, Los Angeles, CA 90017

This report contains sample findings and is **NOT** intended to be a comprehensive site inspection and is **NOT** intended to be a complete report. This site survey was conducted on December 14, 2009.

Prepared By  
**Disability Access Consultants, Inc.**  
(800) 743-7067





## Doors

Bottom 10 inches of the door not smooth



## Restroom

No 60 inch clearance



## Restroom

Grab bars do not extend 54 inches from the back wall



## **Elevator**

Non-accessible call box compartment



## **Restroom**

Pipes not wrapped under lavatory



## **Stairs**

Non compliant handrails

Open risers



### **Office Counter**

Office counter is too high and exceeds 34 inches



### **Signage**

No room signage



### **Dining Area**

No accessible tables