

Accessibility Site Survey of Selected Items For Title 24 of the California Building Code



LA Leadership Academy
668 South Catalina Street
Los Angeles, CA 90005

Certificate of Occupancy: 8-Existing School

This report contains sample findings and is **NOT** intended to be a comprehensive site inspection and is **NOT** intended to be a complete report.

December 15, 2009



Main Entrance

Non-accessible main entrance
No level landing
Door not wide enough and no signage



Main Entrance Door

Not wide enough
Pressure greater than 5 pounds



Parking and Path of Travel

No accessible parking
No accessible route to the main entrance
Gate track is a barrier



Inside Main Entrance - Lobby

Slopes greater than 5%



Access to Office, Classrooms and all Floors

There is stair access only to the school office and the classrooms
Non-compliant handrails



Access to Office

Stair access only to the office



Restrooms

No compliant restrooms for staff or students at the school



Locker Room

No accessible lockers



Stage

Non-accessible stage



Path of Travel

Change in elevation on the primary path of travel to programs, services and activities