

# Accessibility Site Survey of Selected Items For Title 24 of the California Building Code



Anahuacalmecac University Prep High School  
4736 North Huntington Drive  
Los Angeles, CA 90032

Certificate of Occupancy: 7-Change of Use


This report contains sample findings and is **NOT** intended to be a comprehensive site inspection and is **NOT** intended to be a complete report.

January 26, 2010



## Main Entrance

No signage at main entrance




## Signage

No directional signage to main entrance



## Signage

No signage at main office



### **Protruding Object**

Office counter is a protruding office



### **Stairs**

No striping on stairs



### **Drinking Fountain**

Drinking fountain is not in an alcove and is a protruding object



### Restroom

No 12 inch latch side clearance from the push side of the door to the water closet



### Restroom

Centerline of the water closet is 19 3/8 inches



### Grab Bar

No back grab bar