

Accessibility Site Survey of Selected Items For Title 24 of the California Building Code



Anahuacalmecac University Prep High School
4736 North Huntington Drive
Los Angeles, CA 90032

Certificate of Occupancy: 7-Change of Use


This report contains sample findings and is **NOT** intended to be a comprehensive site inspection and is **NOT** intended to be a complete report.

January 26, 2010



Main Entrance

No signage at main entrance



Signage

No directional signage to main entrance



Signage

No signage at main office



Protruding Object

Office counter is a protruding office



Stairs

No striping on stairs



Drinking Fountain

Drinking fountain is not in an alcove and is a protruding object



Restroom

No 12 inch latch side clearance from the push side of the door to the water closet



Restroom

Centerline of the water closet is 19 3/8 inches



Grab Bar

No back grab bar