

Accessibility Site Survey of Selected Items
For
Title 24 of the California Building Code



Celerity Dyad Charter School
4501 Wadsworth Avenue
Los Angeles, CA 90011

Certificate of Occupancy: 7-Change of Use

This report contains sample findings and is **NOT** intended to be a comprehensive site inspection and is **NOT** intended to be a complete report.

January 25, 2010



Main Entrance

Stair access only
Non-compliant handrails



Ramp

No Handrails



Door Threshold

Entrance door to first floor from ramp has a threshold greater than a beveled 1/2 inches



Restroom

Adult standards in children's restroom



Accessible Route

No signage

Non-compliant gate



Signage

No accessible signage at classrooms




Lunch Area

No accessible tables



Student Restrooms

Adult standards instead of children's standards



Protruding Object

Grate on wall is a protruding object