

Accessibility Site Survey of Selected Items
For
Title 24 of the California Building Code



Full Circle Learning Center
4319 West Jefferson Boulevard
Los Angeles, CA 90016

Certificate of Occupancy: 7-Change of Use

This report contains sample findings and is **NOT** intended to be a comprehensive site inspection and is **NOT** intended to be a complete report.

January 27, 2010



Main Entrance

Stair access only



Drinking Fountains

No compliant drinking fountains in school



Restrooms

No compliant student restrooms

No compliant signage



Designated Accessible Route to School

Non-accessible route